



170010260188



(2020)国认监认字(047)号



中国认可  
国际互认  
检测  
TESTING  
CNAS L0846

# TEST REPORT

WQ No.21050080

Product Fiberglass decorative acoustic panel

Client BEIYANG BUILDING MATERIAL CO.,LTD

Test Type Entrusted Testing

Nanjing Guocai Testing Co.,Ltd

China National Fiberglass Product Quality Supervision & Testing Center



July 14, 2021



## Test Report

WQ No.21050080

Page 1 of 2

Client	BEIYANG BUILDING MATERIAL CO.,LTD	Address of client	Dongqing Garden Industrial Area, Zhenglu Town, Tianning District, Changzhou, Jiangsu, China
Product	Fiberglass decorative acoustic panel	Specification	Density: 120kg/m <sup>3</sup> , Thickness: 40mm
Trade mark	ceillex	Sample sender	Zhu Haibao
Producer	BEIYANG BUILDING MATERIAL CO.,LTD	Date of production	---
Inspections required	Formaldehyde emission of the sample.		
Additional information	----		
The above information is provided by the client, the Center is not responsible for its truthfulness.			
Test type	Entrusted Testing	Date of sample received	May 28, 2021
Sample state	Hard plate product with white topcoat on one side		
Sample quantity	(600×600)mm, 6 pieces	Testing period	2021.5.28 - 2021.7.13
Test standard	Requirement by the client		
Testing result	<p>The sample has been tested. The test results conform to the requirement by the client and are detailed in the annex (page 2).</p> <p>Seal for test report July 14, 2021</p> <p>The test results only represent the technical properties of the samples received.</p>		
Remark			

Approved by: 陈建明 /Technical Chief

Checked by: 李勇

Compiled by: 刘雨佳



# Test Report

WQ No.21050080

Page 2 of 2

Test item	Test method	Indicators from entrusting party		Test result	Judgment
Rate of formaldehyde emission	JIS A 1901-2015	F ☆☆☆☆	<5 ug/ (m <sup>2</sup> .h)	Not detected (detection limit: 4 ug/ (m <sup>2</sup> .h))	Pass

(Blank below)

